

# Model Predictive Control of Thermal Energy Storage in Building Cooling Systems

Yudong Ma<sup>\*</sup>, Francesco Borrelli<sup>\*</sup>, Brandon Hancey<sup>◇</sup>, Andrew Packard<sup>\*</sup>, Scott Bortoff<sup>◇</sup>

**Abstract**—A preliminary study on the control of thermal energy storage in building cooling systems is presented. We focus on buildings equipped with a water tank used for actively storing cold water produced by a series of chillers. Typically the chillers are operated each night to recharge the storage tank in order to meet the buildings demand on the following day. A Model Predictive Control (MPC) for the chillers operation is designed in order to optimally store the thermal energy in the tank by using predictive knowledge of building loads and weather conditions. This paper addresses real-time implementation and feasibility issues of the MPC scheme by using a (1) simplified hybrid model of the system, (2) periodic robust invariant sets as terminal constraints and (3) a moving window blocking strategy.

## I. INTRODUCTION

According to the statistics compiled by United Technology Corporation in 2009 [11], the building sector consumes about 40% of the energy used in the United States and is responsible for nearly 40% of greenhouse gas emissions. It is therefore economically and environmentally significant to reduce the building energy consumption.

Reductions of 70% building energy use are required to achieve the goals for the building sector set by a number of organizations, including the California Public Utilities Commission. Achieving this goal requires the development of highly efficient heating and cooling systems, which are more challenging to control than conventional systems [7], [6]. For a wide range of innovative heating and cooling systems, their enhanced efficiency depends on the active storage of thermal energy.

This paper focuses on the modeling and the control of the thermal energy storage on the campus of the University of California, Merced, USA, which consists of a chiller plant, an array of cooling towers, a 7000  $m^3$  chilled water tank, a primary distribution system and secondary distribution loops serving each building on the campus. Two chillers are operated each night to recharge the storage tank which meets campus cooling demand the following day. Although the storage tank enables load shifting to off-peak hours to reduce peak demand, the lack of an optimized operation results in conservatively over-charging the tank where conductive losses erode efficiency.

The objective of this paper is to design a predictive controller in order to minimize energy consumption while

satisfying the unknown but bounded cooling demand of the campus buildings and operational constraints.

The main idea of predictive control is to use the model of the plant to predict the future evolution of the system [10], [1], [8]. At each sampling time, starting at the current state, an open-loop optimal control problem is solved over a finite horizon. The optimal command signal is applied to the process only during the following sampling interval. At the next time step a new optimal control problem based on new measurements of the state is solved over a shifted horizon. The resultant control algorithm is referred to as Model Predictive Control (MPC). Although this paper focuses on the specific architecture of the UC Merced Campus, the main ideas and methodologies can be applied to a wider class of buildings systems which use thermal energy storage. In particular our contributions are: (i) the development of a simple, yet descriptive bimodal switching nonlinear model of the overall cooling system, (ii) the development of a MPC scheme for minimizing energy consumption, (iii) the presentation of preliminary simulation results showing a potential 24.5% energy saving compared to currently adopted policies.

The paper is organized as follows. Section II presents a general introduction to the system, and develops a simplified hybrid model of the system. In Section III the MPC control algorithm is outlined together with the dual stage strategy, the move blocking strategy as well as the terminal constraints computation. Simulation results are presented in Section IV. Finally, conclusions are drawn in Section V.

## II. SYSTEM MODEL

In this section we describe the main components of the UC Merced Campus used to generate and store thermal energy. UC Merced campus has been built with a vision to create living laboratories for energy research. In this paper we focus on the higher level control system which actuates two chillers that are operated at night to take advantage of nighttime electricity rates and lower ambient temperature when filling up the two millions gallon tank of chilled water. The following day, the chilled water is pumped from the tank and distributed throughout the campus. Secondary pumps draw water from the distribution system into each building.

The chilled water is generated via chillers and cooling towers within the primary and condenser loops. The chilled water is stored in a stratified thermal energy storage tank, and is distributed to the buildings throughout campus via the secondary loop. The tertiary loop uses pumps and valves within each building to distribute the chilled water for

<sup>\*</sup> Y. Ma, A. Packard, F. Borrelli are with the Department of Mechanical Engineering, University of California, Berkeley, CA 94720-1740, USA. E-mail: {myd07, fborrelli, apackard}@berkeley.edu.

<sup>◇</sup> B. Hancey and S. Bortoff are with United Technologies Research Center, East Hartford, Connecticut, USA. Email: {HanceyBM, BortoffSA}@utrc.utc.com.

consumption by the cooling coils and air handling units (AHUs). The chilled water is warmed by the air-side cooling load of the buildings and returned to the secondary loop. More details can be found in [9].

The next section presents a dynamic models of the system. Our objective is to develop a simplified yet descriptive model which can be used for real time optimization in a MPC scheme.

### A. Nomenclature

The following variables, parameters and subscripts will be used in this paper.

parameters	description
$\rho$ :	fluid density [kg/m <sup>3</sup> ]
$A_c$ :	cross sectional area of tank [m <sup>2</sup> ]
$k_1$ :	heat transfer coefficient to ambient [W/K]
$k_2$ :	heat transfer coefficient between cool and warm mass of water [W/K]
$C_p$ :	specific heat of water [J/K ]
$r_{tank}$ :	radius of the tank [m]
$S$ :	Weight on the energy consumption
$R$ :	Weight on the control input
$H_p$ :	Length of prediction horizon
$H_u$ :	Length of control horizon
$h$ :	specific enthalpy [J/kg]
$\dot{H}$ :	enthalpy flow rate [W]
$\dot{m}$ :	mass flow rate [kg/s]
$p$ :	pressure [Pa]
$P$ :	power [W]
$U$ :	Internal energy of water [J]
$\dot{Q}$ :	heat flow transferred from one medium to another [W]
$T$ :	Temperature [K]
$m$ :	mass of water
$z$ :	height of water [m]
$\dot{Q}_l$ :	cooling load [W]

TABLE I: Parameters and Variables

subscripts	description
$\cdot_b$ :	water below thermocline
$\cdot_a$ :	water above thermocline
$\cdot_{cmp}$ :	campus
$\cdot_{cmp,r}$ :	campus return
$\cdot_{cmp,s}$ :	campus supply
$\cdot_{CHWS}$ :	chilled water supplied from the chillers
$\cdot_{CHWR}$ :	chilled water returning to the chillers
$\cdot_{amb}$ :	ambient
$\cdot_{wb}$ :	wet bulb

TABLE II: Subscripts

### B. Simplifying Assumptions

The simplified model is based on the following assumptions:

- [A1] The water in the tank is subject to minor mixing and thus can be modeled as a stratified system with layers of warmer water (285 K) at the top and cooler water (277 K) at the bottom. Figure 1 depicts the temperature of the water measured inside the tank at different heights at 8:30am on the 29th of Nov. 2007. One can observe a thin layer of water, known as a thermocline, that has a steep temperature gradient over




Fig. 1: Temperature distribution of water in the tank

the height of the tank. For this reason we lump warmer water above the thermocline and cooler water below the thermocline to obtain a 4-state system describing the height and temperature of the warmer and cooler water, respectively.

- [A2] Lower-level controllers actuate chillers and cooling towers in order to achieve a desired temperature of condensed water produced by cooling towers  $T_{CWS,ref}$ , mass flow rate of chilled water supplied by chillers  $\dot{m}_{CHWS,ref}$  and chilled water temperature  $T_{CHWS,ref}$ . We neglect the dynamics of controlled chillers and cooling towers and assume that there is no tracking error between controlled variables and references. so that:

$$T_{CWS} = T_{CWS,ref} \quad (1a)$$

$$\dot{m}_{CHWS} = \dot{m}_{CHWS,ref} \quad (1b)$$

$$T_{CHWS} = T_{CHWS,ref} \quad (1c)$$

- [A3] Pipes are frictionless and insulated.

- [A4] The campus is considered as a lumped disturbance in terms of heat flux required to cool down all buildings.

### C. Main subsystems of the cooling system

Next we detail the main system components and their models.

1) *Chillers and Cooling Towers Model*: Based on assumption A2, the power used by the pumps, chillers and the cooling towers is modeled as a static function of  $T_{CHWS}$ ,  $T_{CWS}$ ,  $\dot{m}_{CHWS}$ ,  $T_{CHWR}$ :

$$P = Power(T_{CHWS}, T_{CWS}, \dot{m}_{CHWS}, T_{wb}, T_{CHWR}). \quad (2)$$

where  $T_{wb}$  is the temperature read from a wet bulb thermometer. The wet bulb temperature physically reflects the temperature and humidity of the ambient air.

The function  $Power(\cdot)$  is implemented as a 5-D look-up table ( $7 \times 6 \times 6 \times 5 \times 7$ ) obtained by extensive simulations of a high fidelity model under various initial conditions.

2) *Thermal Energy Storage Tank*: We use assumption A1, and also assume that the tank is part of a closed hydronic loop, that is, the mass flow rate entering (exiting) the tank is equal to the mass flow rate exiting (entering) the tank. Subsequently, the height of water in the tank  $z_a + z_b$  is a constant  $z_{tank}$ .

The tank can operate in two modes depending on the control inputs and the disturbances.

a) *Charging*: If the flow rate produced by the chiller is greater than campus flow rate  $\dot{m}_{cmp,s}$ , the difference will be charging the tank. By simple mass and energy conservation law, the dynamic of the tank in charging mode can be modeled as:

$$\dot{H}_b = \dot{m}_b C_p T_{CHWS} \quad (3a)$$

$$\dot{H}_a = \dot{m}_a C_p T_a \quad (3b)$$

$$T_{cmp,s} = T_{CHWS} \quad (3c)$$

$$T_{CHWR} = \frac{T_{cmp,r} \dot{m}_{cmp,r} - T_a \dot{m}_a}{\dot{m}_{CHWR}} \quad (3d)$$

$$\dot{m}_{CHWS} \geq \dot{m}_{cmp,s} \quad (3e)$$

where the variables have been defined in Tables I, II.

b) *Discharging*: If the flow rate produced by the chiller is less than campus flow rate  $\dot{m}_{cmp,s}$ , tank will be discharged. The following equations model the dynamic of the tank in charging mode.

$$\dot{H}_a = \dot{m}_a C_p T_{cmp,r} \quad (4a)$$

$$\dot{H}_b = \dot{m}_b C_p T_b \quad (4b)$$

$$T_{cmp,s} = \frac{T_{CHWS} \dot{m}_{CHWS} - T_b \dot{m}_b}{\dot{m}_{cmp}} \quad (4c)$$

$$T_{CHWR} = T_{cmp,r} \quad (4d)$$

$$\dot{m}_{CHWS} \leq \dot{m}_{cmp,s} \quad (4e)$$

The mass and internal energy conservation laws hold in both modes:

$$\dot{z}_b = (\dot{m}_{CHWS} - \dot{m}_{cmp,s}) / \rho / A_c; \quad (5a)$$

$$\dot{z}_a + \dot{z}_b = 0; \quad (5b)$$

$$\dot{U}_a = \dot{H}_a + \dot{Q}_{b>a} + \dot{Q}_{Amb>a}; \quad (5c)$$

$$\dot{U}_b = \dot{H}_b + \dot{Q}_{a>b} + \dot{Q}_{Amb>b}; \quad (5d)$$

Where  $\dot{Q}_{Amb>a}$  ( $\dot{Q}_{Amb>b}$ ) is the heat transferred from ambient to the warmer (cooler) water in the tank:

$$\dot{Q}_{Amb>a} = (T_{amb} - T_a)(2\pi r_{tank} z_a) k_1$$

and  $\dot{Q}_{a>b}$  ( $\dot{Q}_{b>a}$ ) is the heat conducted from warmer (cooler) water to cooler (warmer) water in the tank:

$$\dot{Q}_{a>b} = (T_a - T_b)(\pi r_{tank}^2) k_2$$

3) *Campus Model*: We use assumption A4 along with a simple energy balance equation, and the campus load can be represented as:

$$\dot{Q}_{cmp} = \dot{m}_{cmp} C_p (T_{cmp,r} - T_{cmp,s}) \quad (6)$$




Fig. 2: Campus Load

where  $\dot{m}_{cmp}$  is mass flow rate to the campus;  $T_{cmp,s}$  is the temperature of water supplied to the campus;  $T_{cmp,r}$  denotes the temperature of water returning to the campus;  $\dot{Q}_{cmp}$  is the summation of the heat load required from each campus building. We use historical data of  $T_{cmp,s}$ ,  $T_{cmp,r}$  and  $\dot{m}_{cmp}$  in order to compute the possible range of  $\dot{Q}_{cmp}$ . Figure 2 plots historical daily campus load during Sep. 2008, and we observe that the load has a period of one day. It is reasonable to model the load as a periodic disturbance with periodic envelope constraints (the bounds are represented with thicker lines in Figure 2).

#### D. Control Variables

1)  $T_{CWS,ref}$ : Reference temperature of the water exiting the cooling tower.

2)  $\dot{m}_{CHWS}$ : Mass flow rate of the chiller water supply. It is a disconnected set. The mass flow rate is 0 when chiller is off, and  $[2, 235]$  while the chiller is operating.

3)  $T_{CHWS,ref}$ : Reference temperature of the water delivered by the chiller.

#### E. Operation Constraints

The following constraints avoid the malfunction of the system components:

- 1)  $T_{CWS,ref} \in [285, 295]K$ ;
- 2)  $\dot{m}_{CHWS} \in \{0\} \cup [20, 235]kg/s$ ;
- 3)  $T_{CHWS,ref} \in [276.5, 280.4]K$ ;
- 4)  $T_{CHWR} \in [283, 295]K$ ;
- 5)  $Z_b \in [0.1, 1]z_{tank}$ .

#### F. Model Summary

By collecting Equations (3)–(6) and discretizing the system with sampling time of 1 hour, the dynamic equations can be compacted as:

$$x(t+1) = f(x(t), u(t), d(t)) \quad (7a)$$

$$y(t) = g(x(t), u(t), d(t)); \quad (7b)$$

where

$$f = \begin{cases} f_1(x(t), u(t), d(t)); & \text{if } \dot{m}_{CHWS} \leq \dot{m}_{cmp} \\ f_2(x(t), u(t), d(t)); & \text{if } \dot{m}_{CHWS} > \dot{m}_{cmp} \end{cases}$$

$$u(t) = [T_{CWS,ref}; \dot{m}_{CHWS}; T_{CHWS,ref}] \in \mathbb{U}$$

$$x(t) = [U_a; U_b; z_a; z_b]$$

$$d(t) = [\dot{m}_{cmp,s}] \in \mathbb{D}(t)$$

$$y(t) = [T_{CHWR}; z_b] \in \mathbb{Y}.$$

SUMMER	Period A	(May 1st though Oct. 31st)
Peak	12:00–18:00	except holidays
Partial-peak	8:30–12:00 AND 18:00–9:30	except holidays
Off-peak	21:30–8:30 ALL DAY	Mon. through Fri. Sat., Sun, and holidays
WINTER	Period B	(Nov. 1st though Apr. 30st)
Partial-peak	8:30–21:30	except holidays
Off-peak	21:30–8:30 ALL DAY	Mon. through Fri. Sat., Sun, and holidays

TABLE III: Definition of time periods

Total Energy Rates (\$ per kWh)	
Peak Summer	\$ 0.13593
Part-Peak Summer	\$ 0.09204
Off-Peak Summer	\$ 0.07392
Part-Peak Winter	\$ 0.08155
Off-Peak Winter	\$ 0.07118

TABLE IV: Total Energy Rates

$\mathbb{U}$  is the feasible control input set defined in Section II-E;  $\mathbb{Y}$  is the feasible output set defined in Section II-E;  $\mathbb{D}(t)$  refers to the time-variant disturbances ranges and is defined in Figure 2.

### G. Energy Price

UC Merced is currently enrolled in a special plan, electric schedule E-20. The customer’s monthly charge for the service under Schedule E-20 is the sum of a customer charge and energy charges, and all the unit price varies depending on the period of time. Table III shows the definition of the time periods. We denote the unit electricity price defined by Table IV as the function  $C(t)$ . The customer pays for energy by the kilowatt hour (kWh).

## III. MPC PROBLEM FORMULATION

This section presents the design of a MPC control whose objective is to find the optimal control sequence that satisfies the required cooling load and minimizes electricity usage. Consider the following optimization problem:

$$J^*(x(t), t) = \min_{\hat{u}_{1|t}, \dots, \hat{u}_{M|t}} \sum_{i=1}^N \{ \|C(t+i)E(x_{i|t}, u_{i|t})\|_S + \|u_{i|t}\|_R \} \quad (9a)$$

s.t.

$$y_{i|t} \in \mathbb{Y}, \forall i = 1, 2, \dots, N \quad (9b)$$

$$u_{i|t} \in \mathbb{U}, \forall i = 1, 2, \dots, N \quad (9c)$$

$$y_{N|t} \in \mathbb{Y}_f(t); \quad (9d)$$

$$E(x_{i|t}, u_{i|t}) = \text{Power}(x_{i|t}, u_{i|t})\Delta T \quad (9e)$$

$$[u'_{1|t}, \dots, u'_{N|t}]' = B \otimes I_m [\hat{u}'_{1|t}, \dots, \hat{u}'_{M|t}] \quad (9f)$$

$$x_{k+1|t} = f(x_{k|t}, u_{k|t}, d(k)); \quad (9g)$$

$$y_{k|t} = g(x_{k|t}, u_{k|t}, d(k)); \quad (9h)$$

$$d(k) \in \mathbb{D}(k), \forall k = 1, 2, \dots, N \quad (9i)$$

where  $\mathbb{Y}_f(t)$  is the terminal constraint set,  $C(t)$  is the energy

price at time  $t$ ,  $\Delta T = 1$  hour,  $S$  is the weight on the energy consumption, and  $R$  is the weight of the control inputs.

Let  $U_{1|t \rightarrow N|t}^* = \{u_{1|t}^*, \dots, u_{N|t}^*\}$  be the optimal solution of Problem (9) at time  $t$ , and  $J_t^*(x(t))$  the corresponding value function. Then, the first element of  $U_{1|t \rightarrow N|t}^*$  is implemented to the system (7):

$$u(t) = u_{1|t}^* \quad (10)$$

The optimization Problem (9) is repeated at time  $t+1$ , with the updated new state  $x_{0|t+1} = x(t+1)$ , yielding a *moving or receding horizon control* strategy.

The proposed MPC controller uses a move blocking strategy to reduce the computational time required for its real time implementation. The control sampling time is one hour, and prediction horizon is set to 24h (one day).

### A. Dual Stage Optimization

Problem (9) is a MINLP (Mix Integer Nonlinear Program), whose complexity limits real time implementation. We solve the Problem (9) by using a tailored branch and bound strategy. In the first stage, we choose the tank operation mode profile, and in the second stage, with a fixed tank operation mode, the problem is recast to a NLP (nonlinear program) problem which can be solved by optimization packages available such as *NPSOL* [5].

In this paper, the results presented use a fixed tank operation mode profile that charges the tank from 23 pm to 2 am the next day.

### B. Move Window Blocking Strategy

The prediction horizon of the proposed MPC controller is 24 hours, and the control sampling time is one hour. As a result, there would be total 72 optimization variables as the control input dimension is 3. It is common practice to reduce the degrees of freedom by fixing the input or its derivatives to be constant over several time steps [12]. In this paper, we are using the Moving Window Blocking approach proposed in [4] to reduce the complexity while retain the persistent feasibility of the resulting MPC. The following definitions will be introduced to better understand the algorithm.

*Definition 1 (Admissible Blocking Matrix):* A matrix  $B \in \{0, 1\}^{N \times M}$  is an admissible blocking matrix if  $M < N$ , and one entry in each row of  $B$  is equal to 1, the elements of the matrix are arranged in an "upper staircase" form, i.e. if the column in which a 1 occurs in the  $i$ 'th row is

$$j^*(i) := \{j | B_{i,j} = 1\}$$

then  $j^*(i+1) \geq j^*(i)$  for all  $i \in \{1, 2, \dots, N-1\}$ . where  $B_{i,j}$  denotes the element of  $i$ 'th row and  $j$ 'th column of matrix  $B$ .

*Definition 2 (Blocking Length Vector):* Given an admissible blocking matrix  $B \in \{0, 1\}^{N \times M}$ , the blocking length vector  $L(B)$  is defined as the columnwise summation of the matrix  $B$ . An admissible block vector corresponds to a unique blocking length matrix.

The following algorithm is implemented in the proposed MPC.

*Algorithm 1 (Moving Window Blocking):* Given an initial blocking length matrix  $L_0$ ;

1) let  $i = 0$ ;

2) if  $L_i(1) > 1$ ,

$$L_{i+1} := L_i;$$

$$L_{i+1}(1) := L_i(1) - 1;$$

$$L_{i+1}(end) := L_i(end) + 1.$$

if  $L_i(1) = 1$ ,

$$L_{i+1} := [L_i(2 : end), L_i(1), 0].$$

3) if  $L_i = L_0$ , stop. Otherwise, go to next step;

4) let  $i := i + 1$ , and go to step 2.

where  $L_i(end)$  is the last element of  $L_i$ .

By following Algorithm 1, we can get a series of blocking length matrices for each step. In this work, we choose  $L_0 = [2, 2, 18, 1, 1, 0]$ , and Algorithm 1 will give

$$L_1 = [1, 2, 18, 1, 1, 1] \implies L_2 = [2, 18, 1, 1, 2, 0]$$

$$\implies \dots \implies L_{24} = [2, 2, 18, 1, 1, 0]$$

By applying this algorithm, the computational time of a single optimization problem is reduced from 10 min to 2 min.

### C. Terminal Constraints

It is well known that stability and feasibility are not ensured by the MPC law without terminal cost or terminal constraints. Usually the problem is augmented with a terminal cost and a terminal constraint set  $\mathbb{Y}_f$ . Typically  $\mathbb{Y}_f$  is a robust control invariant set which guarantees that if Problem (9) is feasible for a given  $x_0$ , then it is always feasible for  $t \geq 0$  [13].

The formal definition for invariant set can be found in [10], [2]. A treatment of sufficient conditions which guarantees persistent feasibility of MPC problems goes beyond the scope of this work and can be found in [13]. Since the disturbance is periodic, the idea in [3] can be applied to the proposed MPC controller. The invariant set, if exists, will be time variant and periodic with the same period as the disturbances.

In order to guarantee that the tank has enough cold water to satisfy the demand, we use the algorithm proposed in [3] to calculate the CPI (Controlled Periodic Invariant) sets for the system described in Equations (5a). The system is a buffer subject to constraints defined in Section II-E and periodic disturbance modeled in Figure 2.

We implemented the algorithm proposed in [3] and Figure 3 plots the lower bound of the computed periodic set  $\mathbb{Y}_f(t)$ . If the height of the cooler water in the tank is greater than the lower bounds, there exists a feedback control law that will satisfy any disturbance belonging to the envelope in Figure 2 without violating the states and inputs constraint.




Fig. 3: Lower bound of the CPI set ( $\mathbb{Y}_f(t)$ )

## IV. SIMULATION RESULTS

Define the one day Electricity Bill as

$$Bill = \sum_{t=0}^{t=24} C(t)Power(x_t, u_t)\Delta T \quad (12)$$

where  $\Delta T$  is the sampling time (1 hour).


Next we simulate system (7) in closed loop with the MPC controller (9), (7) and compare the results with current manual operation over 7 days. The load of the campus is chosen to be the maximum of the load shown in Figure 2 in order to test the robustness of the controller. The temperature of wet bulb is extracted from the historical data and will be replaced by the data from weather stations in future work.

1) *Current Manual Operation:* The cooling system at UC Merced is operated manually as follows. The temperature set-points  $T_{CWS,ref}$  and  $T_{CHWS,ref}$  are kept constant to 286.26K and 277.04K respectively; the chillers will be ON from 10pm to 2am every two days to charge the tank to full with a constant mass flow rate of 138Kg/s and the chiller is OFF the rest of time. Simulation results plotted in Figure 4(a) shows that the system converges to a periodic operation. The tank is charged to full during the night, and discharged at daytime. Based on Equation (12), the average bill in one day for this heuristic control sequence is \$174.54.


2) *Operation With MPC Controller:* Simulation results plotted in Figure 4(b) shows that the system converges to a periodic operation. Figure 5 reports the control inputs of the heuristic control logic and the MPC controller. The system states evolution is shown in Figure 4(b). We can observe that the height and the temperature of the cold water in the tank behaves periodically. The optimal MPC policy does not charge the tank to the full capacity and thus avoids tank losses. Instead, the tank is preferably charged to 35% of the tank volume to achieve better efficiency. Also, the resulting bill under the MPC policy (at periodic steady state) in one day is \$131.71, which corresponds to a saving of 24.5% compared to the heuristic controller.

## V. CONCLUSIONS

In this paper, we introduced a simplified model of the chilling system at UC Merced and a Model Predictive Control algorithm. Periodic invariant sets, moving block strategy and dual stage optimization have been used to tackle complexity and feasibility issues of the resulting scheme. Preliminary simulation results showed that the daily electricity bill can be reduced of 24.5% compared to the current heuristic manual



(a) Simulation results of the heuristic controller



(b) Simulation result of MPC controller

Fig. 4: Simulation results


control sequence. The results is very promising and current work is focusing on model validation in order to confirm that a similar range of performance improvement could be obtained for the actual plant. In particular the building load model requires further investigation and validation. Our near future work will also involve experimental validation of the proposed scheme at UC Merced.

## VI. ACKNOWLEDGMENTS


This work was partial supported by the Department of Energy and Lawrence Berkeley National Laboratories. We thank Philip Haves, John Elliott, Satish Narayanan, Stella M. Oggianu, Brian Coffey and Michael Wetter for constructive and fruitful discussions on the system modeling and control implications.

## REFERENCES


- [1] F. Allgöwer, T.A. Badgwell, S.J. Qin, J.B. Rawlings, and S.J. Wright. *Nonlinear predictive control and moving horizon estimation - and introductory overview*. Springer Berlin/Heidelberg, 1999.
- [2] A. Bemporad and M. Morari. Robust model predictive control: A survey. In A. Garulli, A. Tesi, and A. Vicino, editors, *Robustness in Identification and Control*, number 245 in Lecture Notes in Control and Information Sciences, pages 207–226. Springer-Verlag, 1999.
- [3] F. Blanchini and W. Ukovich. Linear programming approach to the control of discrete-time periodic systems with uncertain inputs. *J. Optim. Theory Appl.*, 78(3):523–539, 1993.



(a) Control input  $T_{CWS}$



(b) Control input  $\dot{m}_{CHWS}$



(c) Control input  $T_{CHWS}$

Fig. 5: MPC Control Sequence

- [4] R. Cagienard, P. Grieder, E.C. Kerrigan, and M. Morari. Move blocking strategies in receding horizon control. *Journal of Process Control*, 17(6):563 – 570, 2007.
- [5] K. Holmstrom. The tomlab optimization environment in matlab. *Adv. Model. Optim.*, 1:47, 1999.
- [6] M. Koschenz and V. Dorer. Interaction of an air system with concrete core conditioning. *Energy and Buildings*, 30(2):139 – 145, 1999.
- [7] M. Koschenz and B. Lehmann. Development of a thermally activated ceiling panel with pcm for application in lightweight and retrofitted buildings. *Energy and Buildings*, 36(6):567 – 578, 2004.
- [8] J.H. Lee, M. Morari, and C.E. Garcia. State-space interpretation of Model Predictive Control. 1992.
- [9] Y. Ma, F. Borrelli, B. Hancey, A. Packard, and S. Bortoff. Model predictive control of thermal energy storage in building cooling systems. Technical report, Sep. 2009. <http://sites.google.com/site/mayudong/publication-1>.
- [10] D.Q. Mayne, J.B. Rawlings, C.V. Rao, and P.O.M. Scokaert. Constrained model predictive control: Stability and optimality. *Automatic*, 36(6):789–814, June 2000.
- [11] J.M. McQuade. A system approach to high performance buildings. Technical report, United Technologies Corporation, Feb. 2009. <http://gop.science.house.gov/Media/hearings/energy09/april28/mcquade.pdf>.
- [12] S.J. Qin and T.A. Badgwell. An overview of industrial model predictive control technology. pages 232–256, 1997.
- [13] S. V. Raković, E. C. Kerrigan, D. Q. Mayne, and K. I. Kouramas. Optimized robust control invariance for linear discrete-time systems: Theoretical foundations. *Automatica*, 43(5):831–841, 2007.